



## Distinctive features

- Modular design
- Hot swap of modules
- Event log for 5 years
- PC readable event log

You can [download the request form](#), fill it and send to our e-mail: [sector-ves@rambler.ru](mailto:sector-ves@rambler.ru), [sector-ves@fcdt.ru](mailto:sector-ves@fcdt.ru), or request a price list directly from the website:

You can [download the request form](#), fill it and send to our e-mail: [sector-ves@rambler.ru](mailto:sector-ves@rambler.ru), [sector-ves@fcdt.ru](mailto:sector-ves@fcdt.ru), or make a request directly from the website:

**CONTACTS:** fax: +7 (495) 551-06-18; **E-mail:** [sector-ves@rambler.ru](mailto:sector-ves@rambler.ru), [sector-ves@fcdt.ru](mailto:sector-ves@fcdt.ru)

## 1. Purpose

- receiving information from [flame sensors MDP](#) (see the appropriate [section of the catalog](#));
- formation of control signals for automatic fire extinguishing equipment;
- status control of automatic fire extinguishing equipment;
- control of light and sound fire alarm devices.

## 2. The main functions of the device

- automatic control of alarm loops and starting lines ("norm", "short circuit", "breakage", "attention", "fire") with a mark of the date and time of the event;
- automatic diagnostics and testing of flame detectors at predetermined time intervals;
- record of service staff activities;
- non-volatile memory for 400 events;
- automatic activation of fire extinguishing installations in each direction at triggering of a couple of detectors at the protected area;
- alarm and alert in case of fire.

## 3. Specifications

№	Name	Value
1	The number of directions under control	4
2	The number of detectors to monitor one zone	2
3	Power supply voltage	-220 V from the mains 50 Hz
4	Power consumed in the standby mode, including 8 sensors MDP	35 W
5	Weight of the device, no more	6 kg
6	Dimensions	450x320x130 mm

[Save the page in the PDF format](#)

[РПКР-М 2399 00000 00 manual](#)

[The certificate of conformity C-RU.ПБ01.В.01847](#)

[Download the presentation "GOA MAG", means and systems of fire extinguishment and explosion prevention FGUP "FCDT "Soyuz"](#)